

CORRIGENDUM

With reference to the Tender No : NSMIMS/IT/2020-21/NOV/ACTIVE/109 Dated Nov 8, 2020 queries received from Bidders answered.

#	Organization	Page NO	Section No	Clauses As per Tender	Clarification Sought	Query Response
1	BIDDER'S QUERIES	7	3.1.4	Performance Security:- 5% of the offered price	Please remove the Performance security clause. or Please consider payment terms as mentioned below a.)10% advance against Performance security and balance 65% against material delivery and invoice, b.)10 % against Installation pro-rata basis, c.)10% after successfully completion of installation, testing, & commissioning and balance d.)5% as retention.	<i>Will be discussed after opening of the price bid</i>
2		7	3.1.5	Validity of Performance security: 3 years after the date of completion of the contractual obligations	Please revise the Validity of Performance security period of completion of project as 3-4 months	<i>No change in this clause.</i>
3				Payment terms	Requested Payment Terms- 75% against material delivery and invoice, 10 % against Installation pro-rata basis, 10% after successfully completion of installation, testing, & commissioning and balance 5% as retention.	<i>Will be discussed after opening of the price bid</i>

4	BIDDER'S QUERIES	7,16	3.16,6.8.1	Tender Validity:-- Mentioned as 90 days from the date of opening in page no. 7, point no. 3.1.6 and mentioned as 180 days in page no. 16, point 6.8.1	Please confirm the validity of tender	180 Days
5		9,11	5.1.1,5.2.21	Delivery of materials:- Mentioned the delivery of material in 30 Days in point no. 5.1.1 and 30-40 days in point no. 5.2.21.	Please amend the delivery as Required 6 - 8 weeks time frame considering the long lead items delivery.	Can be considered
6		9	5.1.6	Payment Terms:- (a) No advance will be payable. (b) On receipt of complete materials at the site 70% of cost will be paid. (c.) Further 25% will be paid on completion of Testing, commissioning, and installations. (d.) 5% will be released on completion of warranty period.	Please consider a.) 75% against material delivery and invoice, b.) 10 % against Installation pro-rata basis, c.) 10% after successfully completion of installation, testing, & commissioning and balance d.) 5% as retention.	Will be discussed after opening of the price bid
7		9	5.2.1	Pre Qualification of OEM	Please mention the documents is required as for OEM criteria	Yes
8		9	5.2.3	Pre Qualification of OEM	Please confirm shall we provide the catalogue.	Yes
9		9	5.2.3	OEM shall propose their premium line of global product, Regional Specific product shall no be proposed	As per TRAI, Frequency allocation for AP based on the region Specific(India Specific) AP is available as a Region specific, please amend this statement	Only applicable to the Wifi system rest will remain as it is.
10		10	5.2.7	OEM Warranty	Please confirm that OEM MAF is enough to prove the same.	MAF is enough

11	BIDDER'S QUERIES	10	5.2.10	A valid certificate of Manufacture Authorization form should be enclosed	Please mention which segment of the OEM required MAF	<i>All the Active & Passive products</i>
12		10	5.2.11	Letter stating that the product quoted is not end of life should be produced from the OEM	Please mention which segment of the OEM required End of life letter for the products and specify which are the products.	<i>Only for the Active devices.</i>
13		10	5.2.15	[Similar order means "Supply, installation and commissioning of ELV Infrastructure Network components". (Bidder to submit self-attested copy of PO and Completion Certificate from the Client)] Completion certificate is mandatory for two hospital projects with reference letter	Please revise the point as "Completion certificate is mandatory for one hospital with 5 crore value and two hospital projects with 3 crore value projects with reference letter"	<i>Both will be considered</i>
14		11	5.2.18	The Bidder must have a turnover of Rs 50 Crore, in at least two of the last three Financial Years ending on 31.03.2020. Relevant documents should be enclosed	Please revise the criteria as to" Rs 30 Crore, in at least two of the last three Financial Years ending on 31.03.2020. or Rs 50 Crore, in at least one year of the last three Financial Years ending on 31.03.2020. Relevant documents should be enclosed"	<i>Amended in our website.</i>

15	BIDDER'S QUERIES	11	5.2.25	The Bidder shall have Company Registration Certificate with CIN under the Company's Act, valid PAN, PF registration, Professional Tax, ESI, Sales tax Registration Certificate and any other statutory required registration. Copies of the above valid certificate (Code, Name of Company, Expiry Date, etc...) must be submitted as evidence. The bidder shall enclose Income Tax Returns and the audited Balance Sheet for the last Five years	Please confirm whether last 3 years needed as per clause 5.2.18 Balance sheet needed here mentioned last 5 years , please clarify the same by client.	3 Years is enough
16		56	A.2	TV BOQ line item 2- 32" Smart TV Brightness is 450 Nits	32" Smart TV Brightness need 400nits, please change accordingly	400 nits will be considered but we prefer 450 nits.
17		57	B.3	IP TV SERVER / WORKSTATIONS & SIGNAGE SOFTWARE BOQ line item 3 Digital sinage software	Please mentioned the total no:- of License Keys needed in Digital Signage Software.	Minum 6 Maximum 10
t req		58	C.8	CCTV BOQ line item 8- 55" Video wall Brightness is 450 Nits	55" Video Wall Brightness need 500Nits, please change accordingly	Since the proposal has higher brightness, the integrator can quote it. It don't required special approval

19	BIDDER'S QUERIES	58	C.8	CCTV BOQ line item 8- 55" Video wall Media player for data	55" Video Wall 'Media Player for data' please mentioned whether it is Internal or External Media Player.	Media Player don't have much important on CCTV Video Wall. Without Media Player also acceptable. But ensure that the purpose and requirements has addressed.
20		59,60	D.1,2	PA System BOQ line item 1- speaker is 105mm dia with EN54 complied.	Please confirm it shall be EN54 certified or Complied.	EN54 Complied means it complied to EN standard
21		61	F.4	NURSE CALLING SYSTEM BOQ line item 4-asked for IP65/IP67 rating for the patient handsets	Please approve to quote with IP-54 rating	If the Handset is complied with the Anti-Bacterial surface coating, then it can be approved
22		61	G.2	ACCESS CONTROL BOQ line item 2 POE based controller	Please approve to quote NON- POE controller	If the power / Provisions available for the access controller, it can be allowed. Otherwise, can't.
23		68	P.1	Network switch BOQ line item 1 is only for two quantity of 48 port NON POE switch	Please specify any POE switch is needed for connecting CCTV and AP in the network or confirm it is already existing.	Not required to quote the PoE Switches. Already we have.
24		77	6.8	Should also have one alarm in and alarm out options	Camera is use outside, Alarm in/out is not mandatory, please revise the same.	Please comply with specification
25		78	7.8	Shall support one way audio and one alarm in and alarm out options	Camera is use outside, Alarm in/out is not mandatory, please revise the same.	Please comply with specification
26		79	7.14	Power Consumption shall be less than 6W	Please change the Power Consumption shall be less than 9W	Please comply with specification, except 4MP Cameras.
27		80	8.9	Shall support one-way audio and one alarm in and alarm out options	Camera is going to be used for ANPR function, Alarm in/out is not mandatory, Please revise the same.	Please comply with specification

28	BIDDER'S QUERIES	80	8.15	Power Consumption shall be less than 6W	Please change the Power Consumption shall be less than 9W	<i>Can be approved</i>
29		82	10.2	NVR Shall be with 350 Mbps or better bandwidth	Please change the clause as: NVR "Shall be with 320 Mbps or better bandwidth"	<i>Can be approved</i>
30		104	21.3	Each WLC should have minimum of 2x 10/100/1000 RJ45 Ethernet Ports or more Controller/solution should support 198 Access points from day one and be scalable to support up to 1024 APs or more with single hardware or with clusters of hardware, WLC should also support seamless roaming access over L2/L3 network.	As per the std 1000 Aps are considered instead of 1024 , please confirm the change.	<i>Can be considered</i>
31		104	21.5	Controller should have capacity to handle minimum 20,000 or more Concurrent devices and 1500 WLAN	Please confirm 1500 WLAN is specified.	<i>Confirmed.</i>
32		107	21.28	The WLAN solution should provide differentiated access for Guests and staff group on same SSID, Guests should have restricted access like not able to telnet & SSH to servers while connecting on same SSID. Similarly other ROLE BASED ACCESS policy support should be available for differentiated access.	Please provide how many concurrent users may access this network	<i>20,000 or more.</i>

33	BIDDER'S QUERIES	109	22.8	Access point should have minimum 2*1 Gigabit ethernet port and support LACP	Please change the access point should have 1 Gigabit ethernet port	<i>We prefer 2 x1 Gigabit ethernet ports. But we will consider the quote with 1 Gig ports</i>
34		110	22.17	Should support up to 500 clients per AP	As per standard this should be considered as 256 client per radio.	<i>We will accept the quote for the 256 client per device.</i>
35		111	22.21	Shall support 30 SSID's per AP and the AP shall support DHCP and NAT	As per standard like 16 SSID per radio and DHCP and NAT need to be removed	<i>16 SSID will be considered but DHCP and NAT functions included</i>
36		111	22.23	Access point to support- Flash - 256MB and RAM -512MB and 1 USB port also.	Please remove as it is OEM based	<i>Lower configuration may considered but we prefer given specification as it is.</i>
37		156	48.6	Video Conferencing System	Please mention the HDMI port needed,shall we consider 2.	<i>Can be approved</i>
38		200	9	KVM Switch Makes are ATEN,RARITAN,APC	Please add Netrack make in the preferred Makelist	<i>Comply the specification as per tender</i>
39		9	5.1.6	Payment Installments a. No Advance will be payable	Request for a. 10% Advance b. 70% against supply of individual items less propionate advance c. 20% against installation less propionate advance d. 5% against testing & Commissioning e. 5% Retention	<i>Will be discussed after opening the price bid</i>
40		11	5.2.16	The Bidder should have been in the business for a period of not less than 10years as on tender publication date (Supporting documents to be enclosed)	Request to change it to 7 Years	<i>Amended (Please refer our amendment published in hospital website)</i>

41	BIDDER'S QUERIES	11	5.2.18	The bid must have a turn over of Rs. 50 crore. In atleast two of the last three financial years ending on 31.03.2020. Relevant documents to be enclosed	Request to change it to Rs.30 Crore	<i>Amended (Please refer our amendment published in hospital website)</i>
42		16	6.5	Earnest Money Deposit	Request for exception of EMD for MSME & NSIC registered companies	<i>All bids must be accompanied by Tender Fees. EMD will be exempted for the MSME & NSIC.</i>
43		200	9	List of Approved Makes	Request for below makes to be added in approved make list	<i>Stick to the Approved Make List</i>
44				2. CCTV System - Norden, Infinova, Samsung	Hikvision/ CP Plus	<i>Comply the specification as per tender</i>
45				6. Nurse Calling System - Shrack, Honeywell, Ascom	Norris	<i>Comply the specification as per tender</i>
46				13. Thermal Screening System - Norden, Infinova, Samsung	Hikvision/ CP Plus	<i>Comply the specification as per tender</i>

Secretary.
NS MEMORIAL INSTITUTE OF MEDICAL SCIENCE.